

INSTALLATION INSTRUCTIONS

ICSS-X-100-4500 Restraint/Isolators are Pre-Compressed products. Isolator Top plate is under pressure caused by compressed springs. The following steps must be followed carefully for proper installation:

- 1. Do not remove** Spacers/Shipping Blocks from isolators until **step #10** as they are the key indicators for proper adjustment on springs
- Refer to submittal package prepared by ISOTECH Industries and locate each isolator based on model # and identification tag provided
- Secure Isolators to the supporting structure using (4) four 5/8" dia. bolts.
 - Refer to submittal package if isolators are supported by concrete structure for anchor size and installation instructions
- Use crane, gantry or other proper lifting machine to elevate equipment and/or equipment supporting structure
- Carefully lower the equipment and/or equipment supporting structure and properly locate it on top of isolators. Use
 - (2) two 1/2" dia. bolts to secure the equipment and/or equipment supporting structure to each isolator
- DO NOT** shift or move isolators laterally When equipment weight is supported by isolators.
- Ensure isolator top plate is fully covered by equipment and/or equipment supporting structure as shown in pictures below. For installations
 - where less than 80% of isolator top plate is covered, refer to Step 11 shown on the third page:




Fig 2.




Fig 1.





Fig 3.


PROJECT INFORMATION		EQUIPMENT INFORMATION		Canada location	USA Location
Customer:		Type:		35 Siltan Road Woodbridge ON L4L 7Z8 CANADA T: 905-856-5001	3021 E Coronado St. Anaheim, CA.,92806 U.S.A T: 949-788-2930
Project:		Qty Required:			
Drawing No:		Operating Weight:			
Notes:					





Tool free : 1-888-831-3311
www.isotechindustries.com

COPYRIGHT: UNLESS OTHERWISE AGREED OR STATED IN WRITING, ALL INFORMATION AND DESIGNS DISPLAYED WITHIN ARE ALL THE PROPERTY OF ISOTECH INDUSTRIES INC. AND MAY NOT BE DUPLICATED OR DISTRIBUTED OUTSIDE OF ISOTECH INDUSTRIES INC. WITH THE EXCEPTION OF AUTHORIZED PERSONS WITH LEGITIMATE NEED TO KNOW WHO BY THE USE OF THIS RECOGNIZE ISOTECH INDUSTRIES INC. OWNERSHIP AND WILL COMPLY TO MAINTAIN THIS INFORMATION AND DESIGN IN STRICT CONFIDENCE.


8. Loosen the two **Lock Nuts** located inside each stanchion as shown in the picture and move it down to have 1/8" to 3/16" gap between washer and bottom of **Isolator Neoprene Grommet**



9. With Spacers/ Shipping Blocks in place, follow star pattern sequence shown below and turn **Spring Adjustment Bolt** one or two turns on each isolator. DO NOT turn **Spring Adjustment Bolt** more than two turns at a time




PROJECT INFORMATION		EQUIPMENT INFORMATION		Canada location	USA Location
Customer:		Type:		35 Silton Road Woodbridge ON L4L 7Z8 CANADA T: 905-856-5001	3021 E Coronado St. Anaheim, CA.,92806 U.S.A T: 949-788-2930
Project:		Qty Required:			
Drawing No:		Operating Weight:			
Notes:					



Tool free : 1-888-831-3311
www.isotechindustries.com


COPYRIGHT: UNLESS OTHERWISE AGREED OR STATED IN WRITING, ALL INFORMATION AND DESIGNS DISPLAYED WITHIN ARE ALL THE PROPERTY OF ISOTECH INDUSTRIES INC. AND MAY NOT BE DUPLICATED OR DISTRIBUTED OUTSIDE OF ISOTECH INDUSTRIES INC. WITH THE EXCEPTION OF AUTHORIZED PERSONS WITH LEGITIMATE NEED TO KNOW WHO BY THE USE OF THIS RECOGNIZE ISOTECH INDUSTRIES INC. OWNERSHIP AND WILL COMPLY TO MAINTAIN THIS INFORMATION AND DESIGN IN STRICT CONFIDENCE.

10. Follow Star Pattern Sequence until **Spacers/ Shipping Blocks** can be removed easily




11. Installations where Equipment supporting structure or equipment footing covers less than 80% of Isolator top plate.

- Add a reinforcing plate, with the same dimensions of isolator top plate, on top of isolator top plate as shown below:



- Continue Installation by following Steps 8 through 10

PROJECT INFORMATION		EQUIPMENT INFORMATION		Canada location	USA Location
Customer:		Type:		35 Siltan Road Woodbridge ON L4L 7Z8 CANADA T: 905-856-5001	3021 E Coronado St. Anaheim, CA.,92806 U.S.A T: 949-788-2930
Project:		Qty Required:			
Drawing No:		Operating Weight:			
Notes:					



Tool free : 1-888-831-3311
www.isotechindustries.com

